

Certificate of Product Approval

Certificate Number: 946c

Issue: 05

NEXANS TURKIYE ENDUSTRI VE TICARET A.S.

Bozburun Mahallesi
Ahmet Nuri Erikoglu Caddesi No: 2
Denizli
Turkey



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
NX300 Single Core
NX300 Multi Core

Standard(s) (see Appendix for details)

BS 6387:2013
EN 61034-2:2005+A1:2013
EN 60754-1:2014
EN 60754-2:2014
EN 60332-3-23:2009
EN 60332-3-24:2009
EN 50200:2015 (Class PH120)
IEC 60331-21:1999

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha
Senior Certification Manager

11 June 2024
Date of Issue

29 June 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 946c NEXANS TURKIYE ENDUSTRI VE TICARET A.S.

Issue: 05

Product name								LPCB Ref. No.
NX300 Single Core								946c/01
Nominal csa of conductor (mm ²) See note 1	Core Construction	BS 6387 See note 4 & 5	EN 61034-2	EN 60754-1	EN 60754-2	EN 60332-3-24	IEC 60331-21 See note 2	EN 50200
1.5	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
2.5	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
4.0	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
6.0	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
10	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
16	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
25	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
35	One	CWZ	>60%	<0.5% HCl	Complies	-	Complies	PH120
50	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-
70	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-
95	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-
120	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha
Signed for BRE Global Ltd.

Obada Piracha
Senior Certification Manager

11 June 2024
Date of Issue

29 June 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 946c NEXANS TURKIYE ENDUSTRI VE TICARET A.S.

Issue: 05

Product name								LPCB Ref. No.
NX300 Single Core								946c/01
Nominal csa of conductor (mm ²) See note 1	Core Construction	BS 6387 See note 4 & 5	EN 61034-2	EN 60754-1	EN 60754-2	EN 60332-3-24	IEC 60331-21 See note 2	EN 50200
150	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-
185	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-
240	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-
300	One	C	>60%	<0.5% HCl	Complies	Complies	Complies	-
400	One	-	>60%	<0.5% HCl	Complies	Complies	Complies	-
500	One	-	>60%	<0.5% HCl	Complies	Complies	Complies	-
630	One	-	>60%	<0.5% HCl	Complies	Complies	Complies	-
800	One	-	>60%	<0.5% HCl	Complies	Complies	Complies	-
1000	One	-	>60%	<0.5% HCl	Complies	Complies	Complies	-

Uo/U 600/1000V

Notes:

1. Stranded conductor only.
2. The NX300 Single-Core cables met the requirements of IEC 60331-21: 1999 when tested at a temperature of 800°C for a duration of 180 + 15 minutes at a voltage rating of 600V.
3. The NX300 Single-Core cables listed also met the requirements of IEC 60332-1-2:2004

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha
Signed for BRE Global Ltd.

Obada Piracha
Senior Certification Manager

11 June 2024
Date of Issue

29 June 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms). To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.
BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com
LPCB is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 946c **NEXANS TURKIYE ENDUSTRI VE TICARET A.S.**

Issue: 05

4. To satisfy the requirement of BS 6387:2013, for Categories CWZ, testing was conducted using a 20mm stainless steel conduit as the other metallic element.
5. Where a single cable is fitted in conduit, only phase to earth voltage was applied

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

	Obada Piracha	11 June 2024	29 June 2016
Signed for BRE Global Ltd.	Senior Certification Manager	Date of Issue	Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 946c NEXANS TURKIYE ENDUSTRI VE TICARET A.S.

Issue: 05

Product name									LPCB Ref. No.
NX300 Multi Core									946c/02
Nominal csa of conductor (mm ²) See note 1	Core Construction	BS 6387	EN 61034-2	EN 60754-1	EN 60754-2	EN 60332-3-23	EN 60332-3-24	EN 50200	IEC 60331-21 See note 2
1.5	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	PH120	Complies
2.5	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	PH120	Complies
4.0	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	PH120	Complies
6.0	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	PH120	Complies
10	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
16	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
25	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
35	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
50	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
70	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
95	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
120	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha
Signed for BRE Global Ltd.

Obada Piracha
Senior Certification Manager

11 June 2024
Date of Issue

29 June 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 946c NEXANS TURKIYE ENDUSTRI VE TICARET A.S.

Issue: 05

Product name									LPCB Ref. No.
NX300 Multi Core									946c/02
Nominal csa of conductor (mm ²) See note 1	Core Construction	BS 6387	EN 61034-2	EN 60754-1	EN 60754-2	EN 60332-3-23	EN 60332-3-24	EN 50200	IEC 60331-21 See note 2
150	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
185	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
240	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
300	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies
400	2, 3 & 4	CWZ	>60%	<0.5% HCI	Complies	Complies	Complies	-	Complies

U_o/U 600/1000V

Notes:

1. Stranded conductor only.
2. The NX300 Multi-Core cables met the requirements of IEC 60331-21: 1999 when tested at a temperature of 800°C for a duration of 180 + 15 minutes at a voltage rating of 600/1000V.
3. The NX300 Multi-Core cables listed also met the requirements of EN 60332-1-2:2004

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha
Signed for BRE Global Ltd.

Obada Piracha
Senior Certification Manager

11 June 2024
Date of Issue

29 June 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@brelobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.

